



# 2022 CALIFORNIA GREEN BUILDING STANDARDS CODE

## NONRESIDENTIAL MANDATORY MEASURES, SHEET 1 (July 2024 Supplement)

Y = YES  
N/A = NOT APPLICABLE  
RESPON. PARTY = RESPONSIBLE PARTY (i.e. ARCHITECT, ENGINEER, OWNER, CONTRACTOR, INSPECTOR ETC.)

CHAPTER 3 GREEN BUILDING SECTION 301 GENERAL		SECTION 302 MIXED OCCUPANCY BUILDINGS		SECTION 303 PHASED PROJECTS		SECTION 305 DECONSTRUCTION AND REUSE OF EXISTING STRUCTURES		SECTION 306.5.1 RACEWAY CONDUIT AND PANEL POWER REQUIREMENTS FOR MEDIUM- AND HEAVY-DUTY EVSE [N]	
Y	N/A	RESPON. PARTY	Y	N/A	RESPON. PARTY	Y	N/A	RESPON. PARTY	Y
<b>301.1 SCOPE.</b> Buildings shall be designed to include the green building measures specified as mandatory in the application checklists contained in this code. Voluntary green building measures are also included in the application checklists and may be included in the design and construction of structures covered by this code, but are not required unless adopted by a city, county, or city and county as specified in Section 101.7.			<b>5.106.1 STORM WATER POLLUTION PREVENTION FOR PROJECTS THAT DISTURB LESS THAN ONE ACRE OF LAND.</b> Newly constructed projects and additions which disturb less than one acre of land, and are not part of a larger common plan of development or sale, shall prevent the pollution of storm water runoff from the construction activities through one or more of the following measures:			<b>5.106.5.1 Electric vehicle (EV) charging: medium-duty and heavy-duty. [N]</b> [BSC-CG] Construction shall comply with Section 5.106.5.1 to facilitate future installation of electric vehicle supply equipment (EVSE). Construction for warehouses, grocery stores and retail stores, office buildings, and manufacturing facilities with planned off-street loading spaces shall also comply with Section 5.106.5.1 for future installation of medium- and heavy-duty EVSE.			
<b>301.3 NONRESIDENTIAL ADDITIONS AND ALTERATIONS. [BSC-CG]</b> The provisions of individual sections of Chapter 5 apply to newly constructed buildings, building additions of 1,000 square feet or greater, and/or building alterations with a permit valuation of \$200,000 or above (for occupancies within the authority of California Building Standards Commission). Code sections relevant to additions and alterations shall only apply to the portions of the building being added or altered within the scope of the permitted work.			<b>5.106.1.1 Local ordinance.</b> Comply with a lawfully enacted storm water management and/or erosion control ordinance.			<b>Exceptions:</b> 1. On a case-by-case basis where the local enforcing agency has determined compliance with this section is not feasible based upon one of the following conditions: a. Where there is no local utility power supply. b. Where the local utility is unable to supply adequate power. c. Where there is evidence suitable to the local enforcing agency substantiating that additional local utility infrastructure design requirements, directly related to the implementation of Section 5.106.5.3, may adversely impact the construction cost of the project.			
A code section will be designated by a banner to indicate where the code section only applies to newly constructed buildings [N] or to additions and/or alterations [A]. When the code section applies to both, no banner will be used.			<b>5.106.1.2 Best Management Practices (BMPs).</b> Prevent the loss of soil through wind or water erosion by implementing an effective combination of erosion and sediment control and good housekeeping BMPs.			When EVSE(s) is/are installed, it shall be in accordance with the <i>California Building Code</i> , the <i>California Electrical Code</i> and as follows:			
<b>301.3.1 Nonresidential additions and alterations that cause updates to plumbing fixtures only:</b>			<b>1.</b> Soil loss BMPs that should be considered for implementation as appropriate for each project include, but are not limited to the following:			<b>5.106.5.5 Electric vehicle (EV) charging readiness requirements for warehouses, grocery stores, office buildings, and manufacturing facilities and retail stores with planned off-street loading spaces. [N]</b>			
Note: On and after January 1, 2014, certain commercial real property, as defined in Civil Code Section 101.3, shall have its nonresidential plumbing fixtures replaced with appropriate water-conserving plumbing fixtures under specific circumstances. See Civil Code Section 101.1, et seq. for definitions, types of commercial real property affected, effective dates, circumstances necessitating replacement of noncompliant plumbing fixtures, and duties and responsibilities for ensuring compliance.			<b>a.</b> Scheduling construction activity during dry weather, when possible. <b>b.</b> Preservation of natural features, vegetation, soil, and buffers around surface waters. <b>c.</b> Drainage swales or lined ditches to control stormwater flow. <b>d.</b> Mulching or hydroseeding to stabilize disturbed soils. <b>e.</b> Erosion control to protect slopes. <b>f.</b> Protection of storm drain inlets (gravel bags or catch basin inserts). <b>g.</b> Perimeter sediment control (perimeter silt fence, fiber rolls). <b>h.</b> Sediment trap or sediment basin to retain sediment on site. <b>i.</b> Stabilization of erosion exits. <b>j.</b> Wind erosion control. <b>k.</b> Other soil loss BMPs acceptable to the enforcing agency.			In order to avoid future demolition when adding EV supply and distribution equipment, spare raceway(s) or busway(s) and adequate capacity for transformer(s), service panel(s) or subpanel(s) shall be installed at the time of construction in accordance with the <i>California Electrical Code</i> . Construction plans and specifications shall include, but are not limited to, the following:			
<b>301.3.2 Waste Diversion.</b> The requirements of Section 5.408 shall be required for additions and alterations whenever a permit is required for work.			<b>2.</b> Good housekeeping BMPs to manage construction equipment, materials, non-stormwater discharges and wastes that should be considered for implementation as appropriate for each project include, but are not limited to, the following:			1. The transformer, main service equipment and subpanels shall meet the minimum power requirement in Table 5.106.5.1 to accommodate the dedicated branch circuits for the future installation of EVSE.			
301.4 PUBLIC SCHOOLS AND COMMUNITY COLLEGES. (see GBSC)			<b>a.</b> Dewatering activities. <b>b.</b> Material handling and waste management. <b>c.</b> Cleaning materials stockpile management. <b>d.</b> Management of washout areas (concrete, paints, stucco, etc.). <b>e.</b> Control of vehicle/equipment fueling to contractor's staging area. <b>f.</b> Vehicle and equipment cleaning performed off site. <b>g.</b> Spill prevention and control. <b>h.</b> Other housekeeping BMPs acceptable to the enforcing agency.			2. The construction documents shall indicate one or more location(s) convenient to the planned off-street loading space(s) reserved for medium- and heavy-duty ZEV charging cabinets and charging dispensers, and a pathway reserved for routing of conduit from the termination of the raceway(s) or busway(s) to the charging cabinet(s) and dispenser(s), as shown in Table 5.106.5.1.			
301.5 HEALTH FACILITIES. (see GBSC)			<b>5.106.2 STORMWATER POLLUTION PREVENTION FOR PROJECTS THAT DISTURB ONE OR MORE ACRES OF LAND.</b> Comply with all lawfully enacted stormwater discharge regulations for projects that (1) disturb one acre or more of land, or (2) disturb less than one acre of land but are part of a larger common plan of development or sale.			3. Raceway(s) or busway(s) originating at a main service panel or a subpanel(s) serving the area where potential future medium- and heavy-duty EVSE will be located and shall terminate in close proximity to the potential future location of the charging equipment for medium- and heavy-duty vehicles.			
<b>SECTION 302 MIXED OCCUPANCY BUILDINGS</b>			<b>Note:</b> Projects that (1) disturb one acre or more of land, or (2) disturb less than one acre of land but are part of a larger common plan of development or sale must comply with the post-construction requirements detailed in the applicable National Pollutant Discharge Elimination System (NPDES) General permit for Stormwater Discharges Associated with Construction and Land Disturbance Activities issued by the State Water Resources Control Board or the Lahontan Regional Water Quality Control Board (for projects in the Lake Tahoe Hydrologic Unit).			4. The raceway(s) or busway(s) shall be of sufficient size to carry the minimum additional system load to the future location of the charging for medium- and heavy-duty ZEVs as shown in Table 5.106.5.1.			
<b>302.1 MIXED OCCUPANCY BUILDINGS.</b> In mixed occupancy buildings, each portion of a building shall comply with the specific green building measures applicable to each specific occupancy.			<b>5.106.2.1 The installation of each DCFC EVSE shall be permitted to reduce the minimum number of required EV capable spaces without EVSE by five and reduce proportionally the required electrical load capacity to the service panel or subpanel.</b>						
<b>303.1 PHASED PROJECTS.</b> For shell buildings and others constructed for future tenant improvements, only those code measures relevant to the building components and systems considered to be new construction (or newly constructed) shall apply.			<b>5.106.2.2 The installation of two low power Level 2 EV charging receptacles shall be permitted to reduce the minimum number of required EV capable spaces without EVSE in Table 5.106.5.3.1 by one.</b>						
<b>303.1.1 Initial Tenant Improvements.</b> The provisions of this code shall apply only to the initial tenant improvements to a project. Subsequent tenant improvements shall comply with the scoping provisions in Section 303.1 non-residential additions and alterations.			<b>5.106.3.3 Use of automatic load management systems (ALMS).</b> ALMS shall be permitted for EVSE. When ALMS is installed, the required electrical load capacity specified in Section 5.106.3.3 for each EVCS may be reduced when serviced by an EVSE controlled by an ALMS. Each EVSE controlled by an ALMS shall deliver a minimum 30 amperes to an EV when charging one vehicle and shall deliver a minimum 3.3 kW while simultaneously charging multiple EVs.						
<b>ABBREVIATION DEFINITIONS:</b>			<b>5.106.3.4 Accessible EVCS.</b> When EVSE is installed, accessible EVCS shall be provided in accordance with the <i>California Building Code</i> , Chapter 11B, Section 11B-228.3.						
HCD Department of Housing and Community Development			<b>Note:</b> For EVCS signs, refer to Caltrans Traffic Operations Policy Directive 13-01 (Zero Emission Vehicle Signs and Pavement Markings) or its successor(s).						
BSC California Building Standards Commission			<b>5.106.5.3.4 Accessible electric vehicle charging station (EVCS).</b> When EVSE is installed, accessible EVCS shall be provided in accordance with the <i>California Building Code</i> , Chapter 11B, Section 11B-228.3.						
DSA-SS Division of the State Architect, Structural Safety			<b>5.106.5.3.5 Electric vehicle charging station signage.</b> Electric vehicle charging stations shall be identified by signage or pavement markings in compliance with Caltrans Traffic Operations Policy Directive 13-01 (Zero Emission Vehicle Signs and Pavement Markings) or its successor(s).						
OSHPD Office of Statewide Health Planning and Development			<b>Power allocation method shall include the following:</b> 1. Use any KVA combination of EV capable spaces, low power Level 2, Level 2 or DCFC EVSEs. 2. At least one Level 2 EVSE shall be provided.						
LR Low Rise			<b>5.106.5.3.6 Electric vehicle charging stations (EVCS)—power allocation method.</b> The power allocation method may be used as an alternative to the requirements in Section 5.106.5.3.1, Section 5.106.5.3.2 and associated Table 5.106.5.3.1. Use Table 5.106.5.3.6 to determine the total power in KVA required based on the total number of actual parking spaces.						
HR High Rise									
AA Additions and Alterations									
N New									
<b>CHAPTER 5 NONRESIDENTIAL MANDATORY MEASURES</b>									
<b>DIVISION 5.1 PLANNING AND DESIGN</b>									
<b>SECTION 5.101 GENERAL</b>									
<b>5.101.1 SCOPE.</b> The provisions of this chapter outline planning, design and development methods that include environmentally responsible site selection, building design, building siting and development to protect, restore and enhance the environmental quality of the site and respect the integrity of adjacent properties.									
<b>SECTION 5.102 DEFINITIONS</b>									
<b>5.102.1 DEFINITIONS</b>									
The following terms are defined in Chapter 2 ( <i>and are included here for reference</i> )									
<b>CUTOFF LUMINAIRES.</b> Luminaires whose light distribution is such that the candela per 1000 lamp lumens does not numerically exceed 25 (2.5 percent) at an angle of 90 degrees above nadir, and 100 (10 percent) at a vertical angle of 80 degrees above nadir. This applies to all lateral angles around the luminaire.									
<b>ELECTRIC VEHICLE (EV), [BSC-CG, HCD]</b> An automotive-type vehicle for on-road use, such as passenger automobiles, buses, trucks, vans, neighborhood electric vehicles, electric motorcycles and the like, primarily powered by an electric motor that draws current from a rechargeable storage battery, fuel cell, photovoltaic array or other source of electric current. Plug-in hybrid electric vehicles (PHEV) are considered electric vehicles. For purposes of the California Electrical Code, off-road, self-propelled electric vehicles, such as industrial trucks, hoists, lifts, transports, golf carts, airline ground support equipment, tractors, boats and the like, are not included.									
<b>ELECTRIC VEHICLE (EV) CAPABLE SPACE, [BSC-CG, DSA-SS and HCD]</b> A vehicle space with electrical panel space and load capacity to support a branch circuit and necessary raceways, both underground and/or surface mounted, to support EV charging.									
<b>ELECTRIC VEHICLE (EV) CHARGER, [BSC-CG, HCD]</b> Off-board charging equipment used to charge an electric vehicle.									
<b>ELECTRIC VEHICLE CHARGING SPACE (EV SPACE), [HCD]</b> A space intended for future installation of EV charging equipment and charging of electric vehicles.									
<b>ELECTRIC VEHICLE CHARGING STATION (EVCS), [BSC-CG, DSA-SS, HCD]</b> One or more electric vehicle charging spaces served by EVSE or receptacle(s).									
<b>ELECTRIC VEHICLE (EV) READY SPACE, [HCD]</b> A vehicle space which is provided with a branch circuit, any necessary raceways, both underground and/or surface mounted; to accommodate EV charging, terminating in a receptacle or a charger.									
<b>ELECTRIC VEHICLE SUPPLY EQUIPMENT (EVSE), [BSC-CG, DSA-SS and HCD]</b> The conductors, including the ungrounded, grounded and equipment grounding conductors and the electric vehicle connectors, attachment plugs, personnel protection system, and all other fittings, devices, power outlets or apparatus installed specifically for the purpose of transferring energy between the premises wiring and the electric vehicle.									
<b>SECTION 5.105 DECONSTRUCTION AND REUSE OF EXISTING STRUCTURES</b>									
<b>5.105.1 Scope, [BSC-CG]</b> Effective July 1, 2024, alterations(s) to existing building(s) where the combined altered floor area is 100,000 square feet or greater shall comply with either Section 5.105.2, 5.409.2, or 5.409.3. Addition(s) to existing building(s) where the total floor area combined with the existing building(s) is 100,000 square feet or greater shall comply with either Section 5.105.2, Section 5.409.2, or Section 5.409.3. Effective January 1, 2026, the combined floor area shall be 50,000 square feet or greater.									
<b>[DSA-SS]</b> Alteration(s) to existing building(s) where the combined altered floor area is 50,000 square feet or greater shall comply with either Section 5.105.2, 5.409.2, or 5.409.3. Addition(s) to existing building(s) where the total floor area combined with the existing building(s) is 50,000 square feet or greater shall comply with either Section 5.105.2, Section 5.409.2, or Section 5.409.3.									
<b>Exception [BSC-CG, DSA-SS]:</b> Combined addition(s) to existing building(s) of two times the area or more of the existing building(s) is not eligible to meet compliance with Section 5.105.2.									
<b>5.105.2 Reuse of existing building.</b> An alteration or addition to an existing building shall maintain at a minimum 45 percent combined of the existing building's primary structural elements (foundations, columns, beams, walls, and floors; and lateral elements) and existing building enclosure (roof framing, wall framing and exterior finishes). Window assemblies, insulation, portions of buildings deemed structurally unsound and hazardous, and hazardous materials that are remediated as part of the project shall not be included in the calculation.									
<b>5.105.2.1 Verification of compliance.</b> Documentation shall be provided in the construction documents to demonstrate compliance with Section 5.105.2.									
<b>Note:</b> Sample Worksheet WS-3 in Chapter 8 may be used to assist in documenting compliance with this section.									
<b>5.105.3 Deconstruction (Reserved).</b>									
<b>SECTION 306.5.1 RACEWAY CONDUIT AND PANEL POWER REQUIREMENTS FOR MEDIUM- AND HEAVY-DUTY EVSE [N]</b>									
<b>TABLE 5.106.5.3.1</b>									
<b>TOTAL NUMBER OF ACTUAL PARKING SPACES</b>		<b>NUMBER OF REQUIRED EV CAPABLE SPACES PROVIDED WITH EVSE<sup>a</sup></b> <sup>2</sup>							
0-9		0							
10-25		4							
26-50		8							
51-75		13							
76-100		17							
101-150		25							
151-200		35							
201 AND OVER		20 percent of actual parking spaces <sup>1</sup>							
		25 percent of EV capable spaces <sup>1</sup>							
<b>5.106.5.5 Electric vehicle (EV) charging: medium-duty and heavy-duty. [N]</b> [BSC-CG] Construction shall comply with Section 5.106.5.5.1 to facilitate future installation of electric vehicle supply equipment (EVSE). Construction for warehouses, grocery stores and retail stores, office buildings, and manufacturing facilities with planned off-street loading spaces shall also comply with Section 5.106.5.5.1 for future installation of medium- and heavy-duty EVSE.									
<b>Exceptions:</b>									
1. On a case-by-case basis where the local enforcing agency has determined compliance with this section is not feasible based upon one of the following conditions: 									



# 2022 CALIFORNIA GREEN BUILDING STANDARDS CODE

## NONRESIDENTIAL MANDATORY MEASURES, SHEET 2 (July 2024 Supplement)

Y	N/A	RESPON. PARTY
<b>5.106.5.6.2.1 Reduced number of EV capable spaces.</b> The installation of each DCFC EVSE shall be permitted to reduce the minimum number of required EV capable spaces indicated in Table 5.106.5.6.1 by five and reduce proportionally the required electrical load capacity to the service panel or subpanel.		
<b>5.106.5.6.2.2 Multiple connectors.</b> EVSE with multiple vehicle connectors capable of charging multiple EVs simultaneously shall be permitted if the electrical load capacity required by Section 5.106.5.6.1 for each EV capable space is accumulatively supplied to the EVSE.		
<b>5.106.5.6.2.3 Use of automatic load management systems (ALMS).</b> ALMS shall be permitted for EVCS installed in accordance with Section 5.106.5.6.2. When ALMS is installed, the required electrical load capacity specified in Section 5.106.5.6.1 for each EVCS may be reduced when serviced by an EVSE controlled by an ALMS. Each EVSE controlled by an ALMS shall deliver a minimum 30 amperes to an EV when charging one vehicle and shall deliver a minimum 3.3 kW while simultaneously charging multiple EVs.		
<b>5.106.5.6.3 EVCS alternative compliance.</b> In lieu of compliance with Section 5.106.5.6.2, EVCS shall be provided with Level 1, low power Level 2, or Level 2, or any combination of Level 1, low power Level 2 or Level 2 EVSE such that the total power supplied by the combination of EVSE meets the minimum power indicated in Table 5.106.5.6.3, based on the total number of actual parking spaces in each parking facility.		
<b>TABLE 5.106.5.6.3</b>		
NUMBER OF PARKING SPACES IN A PARKING FACILITY		
MINIMUM TOTAL POWER (kVA) REQUIRED FOR EVCS		
0-9		0
10-25		7
26-50		14
51-75		20
76-100		27
101-150		40
151-200		60
201 AND OVER		Total required KVA = P × .05 × 6.6 Where P = Parking spaces in facility

**5.106.5.6.4 EVCS for alterations of or additions to parking facilities.** Alterations of or additions to parking facilities shall provide EVCS in compliance with Section 5.106.5.6.4. The installation of infrastructure for EV capable spaces required to be provided without EVSE shall not be required.

**5.106.5.6.4.1 Alterations of and additions to parking facilities.** EVCS shall be provided in accordance with the number indicated in Table 5.106.5.6.1 or minimum power indicated in Table 5.106.5.6.3 when the scope of work includes an increase in power supply to an electric panel serving light fixtures illuminating the parking area or when area containing parking spaces is added to a parking facility. The number of required EVCS shall be based on the total number of existing and new parking spaces in the parking facility.

**5.106.5.6.4.2 Alterations consisting of the installation of photovoltaic systems.** EVCS shall be provided in accordance with the number indicated in Table 5.106.5.6.1 or maximum power indicated in Table 5.106.5.6.3 when a new photovoltaic system is installed in an existing parking facility.

**5.106.5.6.5 Requirement to install EVSE.** Level 2 EVSE shall be provided in all existing EV capable spaces to create EVCS when a project is required by California Administrative Code Section 4.209 to be submitted for plan approval to the Division of the State Architect. When EVSE is installed in existing EV capable spaces, accessible EVCS shall be provided in accordance with California Building Code Chapter 11b.

**Exception:** Projects in which improvements in parking areas consist only of accessibility improvements are not required to comply with Section 5.106.5.6.5.

**5.106.8 LIGHT POLLUTION REDUCTION. [N]** Outdoor lighting systems shall be designed and installed to comply with the following:

1. The minimum requirements in the California Energy Code for Lighting Zones 0-4 as defined in Chapter 10, Section 10-114 of the California Administrative Code; and
2. Backlight (B) ratings as defined in IES TM-15-11 (shown in Table A-1 in Chapter 8);
3. Uplight and Glare ratings as defined in California Energy Code (shown in Tables 130.2-A and 130.2-B in Chapter 8);
4. Allowable BUG ratings not exceeding those shown in Table 5.106.8, [N] or Comply with a local ordinance lawfully enacted pursuant to Section 101.7, whichever is more stringent.

**Exceptions:** [N]

1. Luminaires that qualify as exceptions in Sections 130.2 (b) and 140.7 of the California Energy Code.
2. Emergency lighting.
3. Building facade meeting the requirements in Table 140.7-B of the California Energy Code, Part 6.
4. Custom lighting features as allowed by the local enforcing agency, as permitted by Section 101.8
5. Luminaires with less than 6,200 initial luminaire lumens.

TABLE 5.106.8 [N] MAXIMUM ALLOWABLE BACKLIGHT, UPLIGHT AND GLARE (BUG) RATINGS 1,2					
ALLOWABLE RATING	LIGHTING ZONE L20	LIGHTING ZONE L21	LIGHTING ZONE L22	LIGHTING ZONE L23	LIGHTING ZONE L24
<b>MAXIMUM ALLOWABLE BACKLIGHT RATING 3</b>					
Luminaire greater than 2 mounting heights (MH) from property line	N/A	No Limit	No Limit	No Limit	No Limit
Luminaire back hemisphere is 1-2 MH from property line	N/A	B2	B3	B4	B4
Luminaire back hemisphere is 0.5-1 MH from property line	N/A	B1	B2	B3	B3
Luminaire back hemisphere is less than 0.5 MH from property line	N/A	B0	B0	B1	B2
<b>MAXIMUM ALLOWABLE UPLIGHT RATING (U)</b>					
For area lighting 3	N/A	U0	U0	U0	U0
For all other outdoor lighting including decorative luminaires	N/A	U1	U2	U3	UR
<b>MAXIMUM ALLOWABLE GLARE RATING 4 (G)</b>					
MAXIMUM ALLOWABLE GLARE RATING 5 (G)	N/A	G1	G2	G3	G4
MAXIMUM ALLOWABLE GLARE RATING 6 (G)	N/A	G0	G1	G1	G2
MAXIMUM ALLOWABLE GLARE RATING 7 (G)	N/A	G0	G0	G1	G1
<b>MAXIMUM ALLOWABLE GLARE RATING 8 (G)</b>	N/A	G0	G0	G0	G1

1. IESNA Lighting Zones 0 and 5 are not applicable; refer to Lighting Zones as defined in the California Energy Code and Chapter 10 of the California Administrative Code.
2. For property lines that abut public walkways, bikeways, plazas and parking lots, the property line may be considered to be 5 feet beyond the actual property line for purpose of determining compliance with this section. For property lines that abut public roadways and public transit corridors, the property line may be considered to be the centerline of the public roadway or public transit corridor for the purpose of determining compliance with this section.
3. General lighting luminaires in areas such as outdoor parking, sales or storage lots shall meet these reduced ratings. Decorative luminaires located in these areas shall meet U-value limits for "all other outdoor lighting".

Y	N/A	RESPON. PARTY
<b>5.106.8.1 Facing-Backlight</b>		
Luminaires within 2MH of a property line shall be oriented so that the nearest property line is behind the fixture, and shall comply with the backlight rating specified in Table 5.106.8 based on the lighting zone and distance to the nearest point of that property line.		
<b>Exception:</b> Corners. If two property lines (or two segments of the same property line) have equidistant point to the luminaire, then the luminaire may be oriented so that the intersection of the two lines (the corner) is directly behind the luminaire. The luminaire shall still use the distance to the nearest point(s) on the property lines to determine the required backlight rating.		
<b>5.106.8.2 Facing-Glare.</b>		
For luminaires covered by 5.106.8.1, if a property line also exists within or extends into the front hemisphere within 2MH of the luminaire then the luminaire shall comply with the more stringent glare rating specified in Table 5.106.8 based on the lighting zone and distance to the nearest point on the nearest property line within the front hemisphere.		
<b>Note:</b> [N]		
1. See also California Building Code, Chapter 12, Section 1205.6 for college campus lighting requirements for parking facilities and walkways.		
2. Refer to Chapter 8 (Compliance Forms, Worksheets and Reference Material) for IES TM-15-11 Table A-1, California Energy Code Tables 130.2-A and 130.2-B.		
3. Refer to the California Building Code for requirements for additions and alterations.		
<b>5.106.10 GRADING AND PAVING.</b>		
Construction plans shall indicate how site grading or a drainage system will manage all surface water flows to keep water from entering buildings. Examples of methods to manage surface water include, but are not limited to, the following:		
1. Swales.		
2. Surface infiltration and disposal systems.		
3. French drains.		
4. Water retention gardens.		
5. Other water measures which keep surface water away from buildings and aid in groundwater recharge.		
<b>Exception:</b> Additions and alterations not altering the drainage path.		
<b>5.106.12 SHADE TREES [DSA-SS].</b>		
Shade Trees shall be planted to comply with Sections 5.106.12.1, 5.106.12.2, and 5.106.12.3. Percentage shade shall be measured at noon on the summer solstice. Landscape irrigation necessary to establish and maintain tree health shall comply with Section 5.304.6.		
<b>5.106.12.1 Surface parking areas.</b>		
Shade tree plantings, minimum #10 container size or equal, shall be installed to provide shade over 50 percent of the parking area within 15 years.		
<b>Exceptions:</b> Surface area covered by solar photovoltaic shade structures with roofing materials that comply with Table A5.106.11.2 in Appendix A5 shall be permitted in whole or in part in lieu of shade tree planting.		
<b>5.106.12.2 Landscape areas.</b>		
Shade tree plantings, minimum #10 container size or equal shall be installed to provide shade of 20% of the landscape area within 15 years.		
<b>Exceptions:</b> Playfields for organized sport activity are not included in the total area calculation.		
<b>5.106.12.3. Hardscape areas.</b>		
Shade tree plantings, minimum #10 container size or equal shall be installed to provide shade over 20 percent of the hardscape area within 15 years.		
<b>Exceptions:</b>		
1. Walks, hardscape areas covered by solar photovoltaic shade structures or shade structures with roofing materials that comply with Table A5.106.11.2 in Appendix A5 shall be permitted in whole or in part in lieu of shade tree planting.		
2. Designated and marked play areas of organized sport activity are not included in the total area calculation.		
<b>5.106.5.6.5 Requirement to install EVSE.</b>		
Level 2 EVSE shall be provided in all existing EV capable spaces to create EVCS when a project is required by California Administrative Code Section 4.209 to be submitted for plan approval to the Division of the State Architect. When EVSE is installed in existing EV capable spaces, accessible EVCS shall be provided in accordance with California Building Code Chapter 11b.		
<b>Exception:</b> Projects in which improvements in parking areas consist only of accessibility improvements are not required to comply with Section 5.106.5.6.5.		
<b>5.106.8 LIGHT POLLUTION REDUCTION. [N]</b>		
Outdoor lighting systems shall be designed and installed to comply with the following:		
1. The minimum requirements in the California Energy Code for Lighting Zones 0-4 as defined in Chapter 10, Section 10-114 of the California Administrative Code; and		
2. Backlight (B) ratings as defined in IES TM-15-11 (shown in Table A-1 in Chapter 8);		
3. Uplight and Glare ratings as defined in California Energy Code (shown in Tables 130.2-A and 130.2-B in Chapter 8);		
4. Allowable BUG ratings not exceeding those shown in Table 5.106.8, [N] or Comply with a local ordinance lawfully enacted pursuant to Section 101.7, whichever is more stringent.		
<b>Exceptions:</b> [N]		
1. Luminaires that qualify as exceptions in Sections 130.2 (b) and 140.7 of the California Energy Code.		
2. Emergency lighting.		
3. Building facade meeting the requirements in Table 140.7-B of the California Energy Code, Part 6.		
4. Custom lighting features as allowed by the local enforcing agency, as permitted by Section 101.8		
5. Luminaires with less than 6,200 initial luminaire lumens.		

Y	N/A	RESPON. PARTY
<b>5.106.8.1 Facing-Backlight</b>		
Luminaires within 2MH of a property line shall be oriented so that the nearest property line is behind the fixture, and shall comply with the backlight rating specified in Table 5.106.8 based on the lighting zone and distance to the nearest point of that property line.		
<b>Exception:</b> Corners. If two property lines (or two segments of the same property line) have equidistant point to the luminaire, then the luminaire may be oriented so that the intersection of the two lines (the corner) is directly behind the luminaire. The luminaire shall still use the distance to the nearest point(s) on the property lines to determine the required backlight rating.		
<b>5.106.8.2 Facing-Glare.</b>		
For luminaires covered by 5.106.8.1, if a property line also exists within or extends into the front hemisphere within 2MH of the luminaire then the luminaire shall comply with the more stringent glare rating specified in Table 5.106.8 based on the lighting zone and distance to the nearest point on the nearest property line within the front hemisphere.		
<b>Note:</b> [N]		
1. See also California Building Code, Chapter 12, Section 1205.6 for college campus lighting requirements for parking facilities and walkways.		
2. Refer to Chapter 8 (Compliance Forms, Worksheets and Reference Material) for IES TM-15-11 Table A-1, California Energy Code Tables 130.2-A and 130.2-B.		
3. Refer to the California Building Code for requirements for additions and alterations.		
<b>5.106.10 GRADING AND PAVING.</b>		
Construction plans shall indicate how site grading or a drainage system will manage all surface water flows to keep water from entering buildings. Examples of methods to manage surface water include, but are not limited to, the following:		
1. Swales.		
2. Surface infiltration and disposal systems.		
3. French drains.		
4. Water retention gardens.		
5. Other water measures which keep surface water away from buildings and aid in groundwater recharge.		
<b>Exception:</b> Additions and alterations not altering the drainage path.		
<b>5.106.12 SHADE TREES [DSA-SS].</b>		
Shade Trees shall be planted to comply with Sections 5.106.12.1, 5.106.12.2, and 5.106.12.3. Percentage shade shall be measured at noon on the summer solstice. Landscape irrigation necessary to establish and maintain tree health shall comply with Section 5.304.6.		
<b>5.106.12.1 Surface parking areas.</b>		
Shade tree plantings, minimum #10 container size or equal, shall be installed to provide shade over 50 percent of the parking area within 15 years.		
<b>Exceptions:</b> Surface area covered by solar photovoltaic shade structures with roofing materials that comply with Table A5.106.11.2 in Appendix A5 shall be permitted in whole or in part in lieu of shade tree planting.		
<b>5.106.12.2 Landscape areas.</b>		
Shade tree plantings, minimum #10 container size or equal shall be installed to provide shade of 20% of the landscape area within 15 years.		
<b>Exceptions:</b> Playfields for organized sport activity are not included in the total area calculation.		
<b>5.106.12.3. Hardscape areas.</b>		
Shade tree plantings, minimum #10 container size or equal shall be installed to provide shade over 20 percent of the hardscape area within 15 years.		
<b>Exceptions:</b>		
1. Walks, hardscape areas covered by solar photovoltaic shade structures or shade structures with roofing materials that comply with Table A5.106.11.2 in Appendix A5 shall be permitted in whole or in part in lieu of shade tree planting.		
2. Designated and marked play areas of organized sport activity are not included in the total area calculation.		
<b>5.106.5.6.5 Requirement to install EVSE.</b>		
Level 2 EVSE shall be provided in all existing EV capable spaces to create EVCS when a project is required by California Administrative Code Section 4.209 to be submitted for plan approval to the Division of the State Architect. When EVSE is installed in existing EV capable spaces, accessible EVCS shall be provided in accordance with California Building Code Chapter 11b.		
<b>Exception</b>		



California

# 2022 CALIFORNIA GREEN BUILDING STANDARDS CODE

## NONRESIDENTIAL MANDATORY MEASURES, SHEET 3 (July 2024 Supplement)

Y YES  
N NOT APPLICABLE  
R RESPONSIBLE PARTY (ie: ARCHITECT, ENGINEER, OWNER, CONTRACTOR, INSPECTOR ETC.)

Y	N/A	RESPON. PARTY	Y	N/A	RESPON. PARTY
<b>5.409.2 Whole building life cycle assessment.</b> Projects shall conduct a cradle-to-grave whole building life cycle assessment performed in accordance with ISO 14040 and ISO 14044, excluding operating energy, and demonstrating a minimum 10-percent reduction in global warming potential (GWP) as compared to a reference baseline building of similar size, function, complexity, type of construction, material specification, and location that meets the requirements of the California Energy Code currently in effect. Software used to conduct the whole building life cycle assessment, including reference baseline building, shall have a data set compliant with ISO 14044, and ISO 21930 or EN 15804, and the software shall conform to ISO 21931 and/or EN 15978. The software tools and data sets shall be the same for evaluation of both the baseline building and the proposed building.		<b>5.409.3 Verification of compliance.</b> Calculations to demonstrate compliance, Type III EPDs for products required to comply, if included in the project, and Worksheet WS-5 signed by the design professional of record shall be provided on the construction documents. Updated EPDs for products used in construction shall be provided to the owner at the close of construction and to the enforcement entity upon request. The enforcing agency may require inspection and inspection reports in accordance with Sections 702.2 and 703.1 during and at completion of construction to demonstrate substantial conformance. Inspection shall be performed by the design professional of record or third party acceptable to the enforcing agency.			
<b>Notes:</b> 1. Software for calculating whole building life cycle assessment is available for free at Athena Sustainable Materials Institute ( <a href="https://calculatela.com/software/impact-estimator/">https://calculatela.com/software/impact-estimator/</a> ) and OneClick LCA-Planetary ( <a href="http://www.oneclicklca.com/planetary">www.oneclicklca.com/planetary</a> ). Paid versions include, but are not limited to, Nastran GaBi Solutions ( <a href="http://gabi.sphera.com">gabi.sphera.com</a> ), Simapro ( <a href="http://simapro.com">simapro.com</a> ), One-Click LCA ( <a href="http://www.oneclicklca.com">www.oneclicklca.com</a> ) and Tally for Revit ( <a href="http://apps.autodesk.com">apps.autodesk.com</a> ).			<b>Exception:</b> Rural jurisdictions that meet and apply for the exemption in Public Resources Code 42649.82 (a)(2)(A) et seq. shall also be exempt from the organic waste portion of this section.		
2. ASTM E2921-22 "Standard Practice for Minimum Criteria for Comparing Whole Building Life Cycle Assessments for Use with Building Codes, Standards, and Rating Systems" may be consulted for the assessment.			<b>5.410.1 ADDITIONS.</b> All additions conducted within a 12-month period under single or multiple permits, resulting in an increase of 30% or more in floor area, shall provide recycling areas on site.		
3. In addition to the required documentation specified in Section 5.409.2.3, Worksheet WS-9 may be required by the enforcing entity to demonstrate compliance with the requirements.			<b>Exception:</b> Additions within a tenant space resulting in less than a 30% increase in the tenant space floor area.		
<b>5.409.2.1 Building components.</b> Building enclosure components included in the assessment shall be limited to glazing assemblies, insulation, and exterior finishes. Primary and secondary structural members included in the assessment shall be limited to footings and foundations, and structural columns, beams, walls, roofs, and floors.			<b>5.410.1.2 Sample ordinance.</b> Space allocation for recycling areas shall comply with Chapter 18, Part 3, Division 30 of the Public Resources Code. Chapter 18 is known as the California Solid Waste Reuse and Recycling Access Act of 1991 (Act).		
<b>5.409.2.2 Reference study period.</b> The reference study period of the proposed building shall be equal to the reference baseline building and shall be 60 years.			<b>Note:</b> A sample ordinance for use by local agencies may be found in Appendix A of the document at the CalRecycle's web site.		
<b>5.409.2.3 Verification of compliance.</b> A summary of the GWP analysis produced by the software and Worksheet WS-4 signed by the design professional of record shall be provided in the construction documents as documentation of compliance. A copy of the whole building life cycle assessment which includes the GWP analysis produced by the software, in addition to maintenance and training information, shall be included in the operation and maintenance manual and shall be provided to the owner at the close of construction. The enforcing agency may require inspection and inspection reports in accordance with Sections 702.2 and 703.1 during and at completion of construction to demonstrate substantial conformance. Inspection shall be performed by the design professional of record or third party acceptable to the enforcing agency.			<b>5.409.2 COMMISSIONING. [N] New buildings 10,000 square feet and over.</b> For new buildings 10,000 square feet and over, building commissioning shall be included in the design and construction processes of the building project to verify that building systems and components meet the owner's or owner representative's project requirements. Commissioning shall be performed in accordance with the section by trained personnel with experience on projects of comparable size and complexity. For I-occupancies that are not regulated by OSHPD or for I-occupancies and L-occupancies that are not regulated by the California Energy Code Section 100.0 Scope, all requirements in Sections 5.410.2 through 5.410.2.6 shall apply.		
<b>Note:</b> For energy-related systems under the scope (Section 100) of the California Energy Code, including heating, ventilation, air conditioning (HVAC) systems and controls, indoor lighting systems and controls, as well as water heating systems and controls, refer to California Energy Code Section 120.8 for commissioning requirements			<b>Commissioning requirements shall include:</b>		
<b>5.409.3 Product GWP compliance—prescriptive path.</b> Each product that is permanently installed and listed in Table 5.409.3 shall have a Type III environmental product declaration (EPD), either product-specific or factory-specific.			<ol style="list-style-type: none"> <li>1. Owner's or Owner representative's project requirements.</li> <li>2. Basis of design.</li> <li>3. Commissioning measures shown in the construction documents.</li> <li>4. Commissioning plan.</li> <li>5. Functional performance testing.</li> <li>6. Documentation and training.</li> <li>7. Commissioning report.</li> </ol>		
<b>TABLE 5.409.3</b> <b>PRODUCT GWP LIMITS</b>			<b>Exceptions:</b>		
<b>BUY CLEAN CALIFORNIA MATERIALS PRODUCT CATEGORY<sup>1</sup></b>	<b>MAXIMUM ACCEPTABLE GWP VALUE (unfabricated) (GWP<sub>allowed</sub>)</b>	<b>UNIT OF MEASUREMENT</b>	<ol style="list-style-type: none"> <li>1. Unconditioned warehouses of any size.</li> <li>2. Areas less than 10,000 square feet used for offices or other conditioned accessory spaces within unconditioned warehouses.</li> <li>3. Tenant improvements less than 10,000 square feet as described in Section 303.1.</li> <li>4. Open parking garages of any size, or open parking garage areas, of any size, within a structure.</li> </ol>		
Hot-rolled structural steel sections	1.77	MT CO <sub>2</sub> e/MT	<b>Note:</b> For the purposes of this section, unconditioned shall mean a building, area or room which does not provide heating and/or air conditioning.		
Hollow structural sections	3.00	MT CO <sub>2</sub> e/MT	<b>Informational Notes:</b>		
Steel plate	2.61	MT CO <sub>2</sub> e/MT	<ol style="list-style-type: none"> <li>1. Functional performance testing for heating, ventilation, air conditioning systems and lighting controls must be performed in compliance with the California Energy Code.</li> </ol>		
Concrete reinforcing steel	1.56	MT CO <sub>2</sub> e/MT	<b>5.410.2.1 Owner's or Owner Representative's Project Requirements (OPR). [N]</b> The expectations and requirements of the building appropriate to its phase shall be documented before the design phase of the project begins. This documentation shall include the following:		
Flat glass	2.50	kg CO <sub>2</sub> e/MT	<ol style="list-style-type: none"> <li>1. Environmental and sustainability goals.</li> <li>2. Building sustainable goals.</li> <li>3. Indoor environmental quality requirements.</li> <li>4. Project program, including facility functions and hours of operation, and need for after hours operation.</li> <li>5. Equipment and systems expectations.</li> <li>6. Building occupant and operation and maintenance (O&amp;M) personnel expectations.</li> </ol>		
Light-density mineral wool board insulation	5.83	kg CO <sub>2</sub> e/MT	<b>5.410.2.2 Basis of Design (BOD). [N]</b> A written explanation of how the design of the building systems meets the OPR shall be completed at the design phase of the building project. The Basis of Design document shall cover the following systems:		
Heavy-density mineral wool board insulation	14.28	kg CO <sub>2</sub> e/MT	<ol style="list-style-type: none"> <li>1. Renewable energy systems.</li> <li>2. Landscape irrigation systems.</li> <li>3. Water reuse system.</li> </ol>		
<b>Concrete, Ready-Mixed<sup>2</sup> 3</b>			<b>5.410.2.3 Commissioning plan. [N]</b> Prior to permit issuance a commissioning plan shall be completed to document how the project will be commissioned. The commissioning plan shall include the following:		
<b>CONCRETE PRODUCT CATEGORY</b>	<b>MAXIMUM GWP ALLOWED VALUE (GWP<sub>allowed</sub>)</b>	<b>UNIT OF MEASUREMENT</b>	<ol style="list-style-type: none"> <li>1. General project information.</li> <li>2. Commissioning goals.</li> <li>3. Systems to be commissioned. Plans to test systems and components shall include: <ol style="list-style-type: none"> <li>An explanation of the original design intent.</li> <li>Equipment and systems to be tested, including the extent of tests.</li> <li>Conditions under which the test shall be performed.</li> <li>Measurable criteria for acceptable performance.</li> <li>Commissioning team information.</li> <li>Commissioning process activities, schedules and responsibilities. Plans for the completion of commissioning shall be included.</li> </ol> </li> </ol>		
up to 2499 psi	450	kg CO <sub>2</sub> e/m <sup>3</sup>	<b>5.410.2.4 Functional performance testing. [N]</b> Functional performance tests shall demonstrate the correct installation and operation of each component, system and system-to-system interface in accordance with the approved plans and specifications. Functional performance testing reports shall contain information addressing each of the building components tested, the testing methods utilized, and include any readings and adjustments made.		
2500–3499 psi	489	kg CO <sub>2</sub> e/m <sup>3</sup>	<b>5.410.2.5 Documentation and training. [N]</b> A Systems Manual and Systems Operations Training are required, including Occupational Safety and Health Act (OSHA) requirements in California Code of Regulations (CCR), Title 8, Section 5142, and other related regulations.		
3500–4499 psi	566	kg CO <sub>2</sub> e/m <sup>3</sup>	<b>5.410.2.6 Systems manual. [N]</b> Documentation of the operational aspects of the building shall be completed within the systems manual and delivered to the building owner or representative. The systems manual shall include the following:		
4500–5499 psi	661	kg CO <sub>2</sub> e/m <sup>3</sup>	<ol style="list-style-type: none"> <li>1. Site information, including facility description, history and current requirements.</li> <li>2. Site contact information.</li> <li>3. Basic operations and maintenance, including general site operating procedures, basic troubleshooting, recommended maintenance requirements, site events log.</li> <li>4. Major systems.</li> <li>5. Site equipment inventory and maintenance notes.</li> <li>6. A copy of verifications required by the enforcing agency or this code.</li> <li>7. Other resources and documentation, if applicable.</li> </ol>		
5500–6499 psi	701	kg CO <sub>2</sub> e/m <sup>3</sup>	<b>5.410.2.7 Systems operations training. [N]</b> A program for training of the appropriate maintenance staff for each equipment type and/or system shall be developed and documented in the commissioning report and shall include the following:		
6500 psi and greater	799	kg CO <sub>2</sub> e/m <sup>3</sup>	<ol style="list-style-type: none"> <li>1. System/equipment overview (what it is, what it does and with what other systems and/or equipment it interfaces).</li> <li>2. Review and demonstration of servicing/preventive maintenance.</li> <li>3. Review of the information in the Systems Manual.</li> <li>4. Review of the record drawings on the system/equipment.</li> </ol>		
<b>Concrete, Lightweight Ready-Mixed<sup>2</sup></b>			<b>5.410.2.8 Commissioning report. [N]</b> A report of commissioning process activities undertaken through the design and construction phases of the building project shall be completed and provided to the owner or representative.		
<b>CONCRETE PRODUCT CATEGORY</b>	<b>MAXIMUM GWP ALLOWED VALUE (GWP<sub>allowed</sub>)</b>	<b>UNIT OF MEASUREMENT</b>	<b>5.410.4 TESTING AND ADJUSTING. New buildings less than 10,000 square feet.</b> Testing and adjusting of systems shall be required for new buildings less than 10,000 square feet or new systems to serve an addition or alteration subject to Section 303.1.		
up to 2499 psi	875	kg CO <sub>2</sub> e/m <sup>3</sup>	<b>5.410.4.2 Reserved</b>		
2500–3499 psi	956	kg CO <sub>2</sub> e/m <sup>3</sup>	<b>5.410.4.2 Systems.</b> Develop a written plan of procedures for testing and adjusting systems. Systems to be included for testing and adjusting shall include at a minimum, as applicable to the project:		
3500–4499 psi	1039	kg CO <sub>2</sub> e/m <sup>3</sup>	<ol style="list-style-type: none"> <li>1. Renewable energy systems.</li> <li>2. Landscape irrigation systems.</li> <li>3. Water reuse systems.</li> </ol>		
<b>1.</b> The GWP values of the products listed in Table 5.409.3 are based on 175 percent of Buy Clean California Act (BCCA) GWP values, except for concrete products which are not included in the BCCA.			<b>5.410.4.3 Procedures.</b> Perform testing and adjusting procedures in accordance with manufacturer's specifications and applicable standards on each system.		
<b>2.</b> For concrete, 175 percent of the National Ready Mixed Concrete Association (NRMCA) 2022 version 3 Pacific Southwest regional benchmark values are used for the GWP allowed, except for High Early Strength.			<b>5.410.4.4 HVAC balancing.</b> In addition to testing and adjusting, before a new space-conditioning system serving a building or space is operated for normal use, the system shall be balanced in accordance with the procedures defined by the Testing Adjusting and Balancing Bureau National Standards; the National Environmental Balancing Bureau Procedural Standards; Associated Air Balance Council National Standards or as approved by the enforcing agency.		
<b>3.</b> Concrete High Early Strength ready-mixed shall be calculated at 130 percent of the ready-mixed concrete GWP allowed values for each product category.			<b>5.410.4.4.1 Reporting.</b> After completion of testing, adjusting and balancing, provide a final report of testing signed by the individual responsible for performing these services.		
<b>5.409.3.1 Products shall not exceed the maximum GWP value specified in Table 5.409.3.</b>			<b>5.410.4.5 Operation and maintenance (O &amp; M) manual.</b> Provide the building owner or representative with detailed operating and maintenance instructions and copies of guarantees/warranties for each system. O & M instructions shall be consistent with OSHA requirements in CCR, Title 8, Section 5142, and other related regulations.		
<b>Exception:</b> Concrete may be considered one product category to meet compliance with this section. A weighted average of the maximum GWP for all concrete mixes installed in the project shall be less than the weighted average maximum GWP allowed per Table 5.409.3 using Exception Equation 5.409.3.1. Calculations shall be performed with consistent units of measurement for the material quantity and the GWP value.			<b>5.410.4.5.1 Inspections and reports.</b> Include a copy of all inspection verifications and reports required by the enforcing agency.		
For the purposes of this exception, industry-wide EPDs are acceptable.			<b>DIVISION 5.5 ENVIRONMENTAL QUALITY</b>		
<b>Exception EQUATION 5.409.3.1</b>			<b>SECTION 5.501 GENERAL</b>		
$GWP_{\text{avg}} = GWP_{\text{allowed}} \text{ where } GWP_{\text{avg}} = \sum (GWP_{\text{mix}}) / (V_n)$ and $GWP_{\text{allowed}} = \sum (GWP_{\text{mix}}) / (V_n)$ and $n = \text{each concrete mix installed in the project}$ $GWP_{\text{mix}} = \text{the GWP for concrete mix } n \text{ per concrete mix EPD, in kg CO}_2\text{e/m}^3$ $GWP_{\text{allowed}} = \text{the GWP potential allowed for concrete mix } n \text{ per Table 5.409.3}$ $V_n = \text{the volume of concrete mix } n \text{ installed in the project, in m}^3$			<b>5.501.1 SCOPE.</b> The provisions of this chapter shall outline means of reducing the quantity of air contaminants that are odorous, irritating, and/or harmful to the comfort and well-being of a building's installers, occupants and neighbors.		
<b>5.409.3.2 Verification of compliance.</b> A summary of the GWP analysis produced by the software and Worksheet WS-4 signed by the design professional of record shall be provided in the construction documents as documentation of compliance. A copy of the whole building life cycle assessment which includes the GWP analysis produced by the software, in addition to maintenance and training information, shall be included in the operation and maintenance manual and shall be provided to the owner at the close of construction. The enforcing agency may require inspection and inspection reports in accordance with Sections 702.2 and 703.1 during and at completion of construction to demonstrate substantial conformance. Inspection shall be performed by the design professional of record or third party acceptable to the enforcing agency.			<b>SECTION 5.502 DEFINITIONS</b>		
<b>5.409.3.3 Product GWP compliance—prescriptive path.</b> Each product that is permanently installed and listed in Table 5.409.3 shall have a Type III environmental product declaration (EPD), either product-specific or factory-specific.			<b>5.502.1 DEFINITIONS.</b> The following terms are defined in Chapter 2 (and are included here for reference)		
<b>TABLE 5.409.3</b> <b>PRODUCT GWP LIMITS</b>			<b>ARTERIAL HIGHWAY.</b> A general term denoting a highway primarily for through traffic usually on a continuous route.		
<b>BUY CLEAN CALIFORNIA MATERIALS PRODUCT CATEGORY<sup>1</sup></b>	<b>MAXIMUM ACCEPTABLE GWP VALUE (unfabricated) (GWP<sub>allowed</sub>)</b>	<b>UNIT OF MEASUREMENT</b>	<b>A-WEIGHTED SOUND LEVEL (dBA).</b> The sound pressure level in decibels as measured on a sound level meter using the internationally standardized A-weighting filter or as computed from sound spectral data to which A-weighting adjustments have been made.		
Hot-rolled structural steel sections	1.77	MT CO <sub>2</sub> e/MT	<b>1 BTU/HOUR.</b> British thermal units per hour, also referred to as Btu. The amount of heat required to raise one pound of water one degree Fahrenheit per hour, a common measure of heat transfer rate. A ton of refrigeration is 12,000 Btu, the amount of heat required to melt a ton (2,000 pounds) of ice at 32° Fahrenheit.		
Hollow structural sections	3.00	MT CO <sub>2</sub> e/MT	<b>COMMUNITY NOISE EQUIVALENT LEVEL (CNEL).</b> A metric similar to the day-night average sound level (Ldn), except that a 5 decibel adjustment is added to the equivalent continuous sound exposure level for evening hours (7pm to 10pm) in addition to the 10 decibel nighttime adjustment used in the Ldn.		
Steel plate	2.61	MT CO <sub>2</sub> e/MT	<b>COMPOSITE WOOD PRODUCTS.</b> Composite wood products include hardwood plywood, particleboard and medium density fiberboard. "Composite wood products" does not include hardwood, structural plywood, structural panels, structural composite lumber, oriented strand board, glued laminated timber, timber, prefabricated wood I-beams or finger-jointed lumber, all as specified in California Code of Regulations (CCR), Title 17, Section 93120.1(a).		
Concrete reinforcing steel	1.56	MT CO <sub>2</sub> e/MT	<b>Note:</b> See CCR, Title 17, Section 93120.1.		
Flat glass	2.50	kg CO <sub>2</sub> e/MT	<b>DAY-NIGHT AVERAGE SOUND LEVEL (Ldn).</b> The A-weighted equivalent continuous sound exposure level for a 24-hour period with a 10 dB adjustment added to sound levels occurring during nighttime hours (10pm to 7am).		
Light-density mineral wool board insulation	5.83	kg CO <sub>2</sub> e/MT	<b>DECIBEL (db).</b> A measure on a logarithmic scale of the magnitude of a particular quantity (such as sound pressure, sound power, sound intensity) with respect to a reference quantity.		
Heavy-density mineral wool board insulation	14.28	kg CO <sub>2</sub> e/MT	<b>ELECTRIC VEHICLE (EV).</b> An automotive-type vehicle for on-road use, such as passenger automobiles, buses, trucks, vans, neighborhood electric vehicles, electric motorcycles, and the like, primarily powered by an electric motor that draws current from a rechargeable storage battery, fuel cell, photovoltaic array, or other source of electric current. Plug-in hybrid electric vehicles (PHEV) are considered electric vehicles. For purposes of the California Electrical Code, off-road, self-propelled electric vehicles, such as industrial trucks, lifts, transports, golf carts, airline ground support equipment, tractors, boats, and the like, are not included.		
<b>Concrete, Ready-Mixed<sup>2</sup> 3</b>			<b>ELECTRIC VEHICLE CHARGING STATION(S) (EVCS).</b> One or more spaces intended for charging electric vehicles.		
<b>CONCRETE PRODUCT CATEGORY</b>	<b>MAXIMUM GWP ALLOWED VALUE (GWP<sub>allowed</sub>)</b>	<b>UNIT OF MEASUREMENT</b>	<b>ELECTRIC VEHICLE EQUIPMENT (EVSE).</b> The conductors, including the ungrounded, grounded, and equipment grounding conductor, and the electric vehicle connectors, attachment plugs, and all other fittings, devices, power outlets, or apparatus installed specifically for the purpose of transferring energy between the premises wiring and the electric vehicle.		
up to 2499 psi	450	kg CO <sub>2</sub> e/m <sup>3</sup>	<b>EQUILIBRATED NOISE LEVEL (Leg).</b> The level of a steady noise which would have the same energy as the fluctuating noise level integrated over the time of period of interest.		
2500–3499 psi	489	kg CO <sub>2</sub> e/m <sup>3</sup>	<b>EXPRESSWAY.&lt;/b</b>		



# 2022 CALIFORNIA GREEN BUILDING STANDARDS CODE

## NONRESIDENTIAL MANDATORY MEASURES, SHEET 4 (July 2024 Supplement)

Y = YES  
N/A = NOT APPLICABLE  
RESPON. PARTY = RESPONSIBLE PARTY (ARCHITECT, ENGINEER, OWNER, CONTRACTOR, INSPECTOR ETC.)

Y	N/A	RESPON. PARTY	<p><b>5.504.4.3 Paints and coatings.</b> Architectural paints and coatings shall comply with VOC limits in Table 1 of the ARB Architectural Coatings Suggested Control Measure, as shown in Table 5.504.4.3, unless more stringent limits for VOC content or VOC content and VOC emissions are met. All other specialty coatings categories listed in Table 5.504.4.3 shall be determined by classifying the coating as a Flat, Nonflat or Nonflat-High Gloss coating, based on its gloss, as defined in Subsections 4.21.4.36 and 4.37 of the 2007 California Air Resources Board Suggested Control Measure, and the corresponding Flat, Nonflat or Nonflat-High Gloss VOC limit in Table 5.504.4.3 shall apply.</p> <p><b>5.504.4.3.1 Aerosol Paints and coatings.</b> Aerosol paints and coatings shall meet the PVMIR limits for VOC content in Table 5.504.4.3 and other requirements, including prohibitions on use of certain toxic compounds and ozone-depleting substances, in Sections 94522(c)(2) and (d)(2) of California Code of Regulations, Title 17, commencing with Section 94520; and in areas under the jurisdiction of the Bay Area Air Quality Management District additionally comply with the percent VOC by weight of product limits of Regulation 8 Rule 49.</p>																																																																																																																	
			<p><b>TABLE 5.504.4.3 - VOC CONTENT LIMITS FOR ARCHITECTURAL COATINGS<sub>2,3</sub></b></p> <table border="1"> <thead> <tr> <th colspan="2">GRAMS OF VOC PER LITER OF COATING, LESS WATER &amp; LESS EXEMPT COMPOUNDS</th> </tr> <tr> <th>COATING CATEGORY</th> <th>CURRENT VOC LIMIT</th> </tr> </thead> <tbody> <tr><td>FLAT COATINGS</td><td>50</td></tr> <tr><td>NONFLAT COATINGS</td><td>100</td></tr> <tr><td>NONFLAT HIGH GLOSS COATINGS</td><td>150</td></tr> <tr><td><b>SPECIALTY COATINGS</b></td><td></td></tr> <tr><td>ALUMINUM ROOF COATINGS</td><td>400</td></tr> <tr><td>BASEMENT SPECIALTY COATINGS</td><td>400</td></tr> <tr><td>BITUMINOUS ROOF COATINGS</td><td>50</td></tr> <tr><td>BITUMINOUS ROOF PRIMERS</td><td>350</td></tr> <tr><td>BOND BREAKERS</td><td>350</td></tr> <tr><td>CONCRETE CURING COMPOUNDS</td><td>350</td></tr> <tr><td>CONCRETE/MASONRY SEALERS</td><td>100</td></tr> <tr><td>DRIVEWAY SEALERS</td><td>50</td></tr> <tr><td>DRY FOG COATINGS</td><td>150</td></tr> <tr><td>FAUX FINISHING COATINGS</td><td>350</td></tr> <tr><td>FIRE RESISTIVE COATINGS</td><td>350</td></tr> <tr><td>FLOOR COATINGS</td><td>100</td></tr> <tr><td>FORM-RELEASE COMPOUNDS</td><td>250</td></tr> <tr><td>GRAPHIC ARTS COATINGS (SIGN PAINTS)</td><td>500</td></tr> <tr><td>HIGH-TEMPERATURE COATINGS</td><td>420</td></tr> <tr><td>INDUSTRIAL MAINTENANCE COATINGS</td><td>250</td></tr> <tr><td>LOW SOLIDS COATINGS:</td><td>120</td></tr> <tr><td>MAGNESIUM CEMENT COATINGS</td><td>450</td></tr> <tr><td>MASTIC TEXTURE COATINGS</td><td>100</td></tr> <tr><td>METALLIC PIGMENTED COATINGS</td><td>500</td></tr> <tr><td>MULTICOLOR COATINGS</td><td>250</td></tr> <tr><td>PRETREATMENT WASH PRIMERS</td><td>420</td></tr> <tr><td>PRIMERS, SEALERS, &amp; UNDERCOATERS</td><td>100</td></tr> <tr><td>REACTIVE PENETRATING SEALERS</td><td>350</td></tr> <tr><td>RECYCLED COATINGS</td><td>250</td></tr> <tr><td>ROOF COATINGS</td><td>50</td></tr> <tr><td>RUST PREVENTATIVE COATINGS</td><td>250</td></tr> <tr><td>SHELLAC:</td><td></td></tr> <tr><td>CLEAR</td><td>730</td></tr> <tr><td>OPAQUE</td><td>550</td></tr> <tr><td>SPECIALTY PRIMERS, SEALERS &amp; UNDERCOATERS</td><td>100</td></tr> <tr><td>STAINS</td><td>250</td></tr> <tr><td>STONE CONSOLIDANTS</td><td>450</td></tr> <tr><td>SWIMMING POOL COATINGS</td><td>340</td></tr> <tr><td>TRAFFIC MARKING COATINGS</td><td>100</td></tr> <tr><td>TUB &amp; TILE REFINISH COATINGS</td><td>420</td></tr> <tr><td>WATERPROOFING MEMBRANES</td><td>250</td></tr> <tr><td>WOOD COATINGS</td><td>275</td></tr> <tr><td>WOOD PRESERVATIVES</td><td>350</td></tr> <tr><td>ZINC-RICH PRIMERS</td><td>340</td></tr> <tr><td>1. GRAMS OF VOC PER LITER OF COATING, INCLUDING WATER &amp; EXEMPT COMPOUNDS</td><td></td></tr> <tr><td>2. THE SPECIFIED LIMITS REMAIN IN EFFECT UNLESS REVISED LIMITS ARE LISTED IN SUBSEQUENT COLUMNS IN THIS TABLE.</td><td></td></tr> <tr><td>3. VALUES IN THIS TABLE ARE DERIVED FROM THOSE SPECIFIED BY THE CALIFORNIA AIR RESOURCES BOARD, ARCHITECTURAL COATINGS SUGGESTED CONTROL MEASURE, FEB. 1, 2008. MORE INFORMATION IS AVAILABLE FROM THE AIR RESOURCES BOARD.</td><td></td></tr> <tr><td><b>5.504.4.3.2 Verification.</b> Verification of compliance with this section shall be provided at the request of the enforcing agency. Documentation may include, but is not limited to, the following:</td><td></td></tr> <tr><td>1. Manufacturer's product specification</td><td></td></tr> <tr><td>2. Field verification of on-site product containers</td><td></td></tr> <tr><td><b>5.504.4.4 Carpet Systems.</b></td><td></td></tr> <tr><td>All carpet installed in the building interior shall meet the requirements of the California Department of Public Health, "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350).</td><td></td></tr> <tr><td>See California Department of Public Health's website for certification programs and testing labs. <a href="https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material">https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material</a></td><td></td></tr> <tr><td><b>5.504.4.4.1 Carpet cushion.</b> All carpet cushion installed in the building interior shall meet the requirements of the California Department of Public Health, "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350).</td><td></td></tr> <tr><td>See California Department of Public Health's website for certification programs and testing labs. <a href="https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material">https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material</a></td><td></td></tr> <tr><td><b>5.504.4.4.2 Carpet adhesive.</b> All carpet adhesive shall meet the requirements of Table 5.504.4.1.</td><td></td></tr> </tbody> </table>	GRAMS OF VOC PER LITER OF COATING, LESS WATER & LESS EXEMPT COMPOUNDS		COATING CATEGORY	CURRENT VOC LIMIT	FLAT COATINGS	50	NONFLAT COATINGS	100	NONFLAT HIGH GLOSS COATINGS	150	<b>SPECIALTY COATINGS</b>		ALUMINUM ROOF COATINGS	400	BASEMENT SPECIALTY COATINGS	400	BITUMINOUS ROOF COATINGS	50	BITUMINOUS ROOF PRIMERS	350	BOND BREAKERS	350	CONCRETE CURING COMPOUNDS	350	CONCRETE/MASONRY SEALERS	100	DRIVEWAY SEALERS	50	DRY FOG COATINGS	150	FAUX FINISHING COATINGS	350	FIRE RESISTIVE COATINGS	350	FLOOR COATINGS	100	FORM-RELEASE COMPOUNDS	250	GRAPHIC ARTS COATINGS (SIGN PAINTS)	500	HIGH-TEMPERATURE COATINGS	420	INDUSTRIAL MAINTENANCE COATINGS	250	LOW SOLIDS COATINGS:	120	MAGNESIUM CEMENT COATINGS	450	MASTIC TEXTURE COATINGS	100	METALLIC PIGMENTED COATINGS	500	MULTICOLOR COATINGS	250	PRETREATMENT WASH PRIMERS	420	PRIMERS, SEALERS, & UNDERCOATERS	100	REACTIVE PENETRATING SEALERS	350	RECYCLED COATINGS	250	ROOF COATINGS	50	RUST PREVENTATIVE COATINGS	250	SHELLAC:		CLEAR	730	OPAQUE	550	SPECIALTY PRIMERS, SEALERS & UNDERCOATERS	100	STAINS	250	STONE CONSOLIDANTS	450	SWIMMING POOL COATINGS	340	TRAFFIC MARKING COATINGS	100	TUB & TILE REFINISH COATINGS	420	WATERPROOFING MEMBRANES	250	WOOD COATINGS	275	WOOD PRESERVATIVES	350	ZINC-RICH PRIMERS	340	1. GRAMS OF VOC PER LITER OF COATING, INCLUDING WATER & EXEMPT COMPOUNDS		2. THE SPECIFIED LIMITS REMAIN IN EFFECT UNLESS REVISED LIMITS ARE LISTED IN SUBSEQUENT COLUMNS IN THIS TABLE.		3. VALUES IN THIS TABLE ARE DERIVED FROM THOSE SPECIFIED BY THE CALIFORNIA AIR RESOURCES BOARD, ARCHITECTURAL COATINGS SUGGESTED CONTROL MEASURE, FEB. 1, 2008. MORE INFORMATION IS AVAILABLE FROM THE AIR RESOURCES BOARD.		<b>5.504.4.3.2 Verification.</b> Verification of compliance with this section shall be provided at the request of the enforcing agency. Documentation may include, but is not limited to, the following:		1. Manufacturer's product specification		2. Field verification of on-site product containers		<b>5.504.4.4 Carpet Systems.</b>		All carpet installed in the building interior shall meet the requirements of the California Department of Public Health, "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350).		See California Department of Public Health's website for certification programs and testing labs. <a href="https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material">https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material</a>		<b>5.504.4.4.1 Carpet cushion.</b> All carpet cushion installed in the building interior shall meet the requirements of the California Department of Public Health, "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350).		See California Department of Public Health's website for certification programs and testing labs. <a href="https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material">https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material</a>
GRAMS OF VOC PER LITER OF COATING, LESS WATER & LESS EXEMPT COMPOUNDS																																																																																																																				
COATING CATEGORY	CURRENT VOC LIMIT																																																																																																																			
FLAT COATINGS	50																																																																																																																			
NONFLAT COATINGS	100																																																																																																																			
NONFLAT HIGH GLOSS COATINGS	150																																																																																																																			
<b>SPECIALTY COATINGS</b>																																																																																																																				
ALUMINUM ROOF COATINGS	400																																																																																																																			
BASEMENT SPECIALTY COATINGS	400																																																																																																																			
BITUMINOUS ROOF COATINGS	50																																																																																																																			
BITUMINOUS ROOF PRIMERS	350																																																																																																																			
BOND BREAKERS	350																																																																																																																			
CONCRETE CURING COMPOUNDS	350																																																																																																																			
CONCRETE/MASONRY SEALERS	100																																																																																																																			
DRIVEWAY SEALERS	50																																																																																																																			
DRY FOG COATINGS	150																																																																																																																			
FAUX FINISHING COATINGS	350																																																																																																																			
FIRE RESISTIVE COATINGS	350																																																																																																																			
FLOOR COATINGS	100																																																																																																																			
FORM-RELEASE COMPOUNDS	250																																																																																																																			
GRAPHIC ARTS COATINGS (SIGN PAINTS)	500																																																																																																																			
HIGH-TEMPERATURE COATINGS	420																																																																																																																			
INDUSTRIAL MAINTENANCE COATINGS	250																																																																																																																			
LOW SOLIDS COATINGS:	120																																																																																																																			
MAGNESIUM CEMENT COATINGS	450																																																																																																																			
MASTIC TEXTURE COATINGS	100																																																																																																																			
METALLIC PIGMENTED COATINGS	500																																																																																																																			
MULTICOLOR COATINGS	250																																																																																																																			
PRETREATMENT WASH PRIMERS	420																																																																																																																			
PRIMERS, SEALERS, & UNDERCOATERS	100																																																																																																																			
REACTIVE PENETRATING SEALERS	350																																																																																																																			
RECYCLED COATINGS	250																																																																																																																			
ROOF COATINGS	50																																																																																																																			
RUST PREVENTATIVE COATINGS	250																																																																																																																			
SHELLAC:																																																																																																																				
CLEAR	730																																																																																																																			
OPAQUE	550																																																																																																																			
SPECIALTY PRIMERS, SEALERS & UNDERCOATERS	100																																																																																																																			
STAINS	250																																																																																																																			
STONE CONSOLIDANTS	450																																																																																																																			
SWIMMING POOL COATINGS	340																																																																																																																			
TRAFFIC MARKING COATINGS	100																																																																																																																			
TUB & TILE REFINISH COATINGS	420																																																																																																																			
WATERPROOFING MEMBRANES	250																																																																																																																			
WOOD COATINGS	275																																																																																																																			
WOOD PRESERVATIVES	350																																																																																																																			
ZINC-RICH PRIMERS	340																																																																																																																			
1. GRAMS OF VOC PER LITER OF COATING, INCLUDING WATER & EXEMPT COMPOUNDS																																																																																																																				
2. THE SPECIFIED LIMITS REMAIN IN EFFECT UNLESS REVISED LIMITS ARE LISTED IN SUBSEQUENT COLUMNS IN THIS TABLE.																																																																																																																				
3. VALUES IN THIS TABLE ARE DERIVED FROM THOSE SPECIFIED BY THE CALIFORNIA AIR RESOURCES BOARD, ARCHITECTURAL COATINGS SUGGESTED CONTROL MEASURE, FEB. 1, 2008. MORE INFORMATION IS AVAILABLE FROM THE AIR RESOURCES BOARD.																																																																																																																				
<b>5.504.4.3.2 Verification.</b> Verification of compliance with this section shall be provided at the request of the enforcing agency. Documentation may include, but is not limited to, the following:																																																																																																																				
1. Manufacturer's product specification																																																																																																																				
2. Field verification of on-site product containers																																																																																																																				
<b>5.504.4.4 Carpet Systems.</b>																																																																																																																				
All carpet installed in the building interior shall meet the requirements of the California Department of Public Health, "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350).																																																																																																																				
See California Department of Public Health's website for certification programs and testing labs. <a href="https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material">https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material</a>																																																																																																																				
<b>5.504.4.4.1 Carpet cushion.</b> All carpet cushion installed in the building interior shall meet the requirements of the California Department of Public Health, "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350).																																																																																																																				
See California Department of Public Health's website for certification programs and testing labs. <a href="https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material">https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material</a>																																																																																																																				
<b>5.504.4.4.2 Carpet adhesive.</b> All carpet adhesive shall meet the requirements of Table 5.504.4.1.																																																																																																																				
<p><b>5.504.4.5 Composite wood products.</b> Hardwood plywood, particleboard and medium density fiberboard composite wood products used on the interior or exterior of the buildings shall meet the requirements for formaldehyde as specified in ARB's Air Toxics Control Measure (ATCM) for Composite Wood (17 CCR 93120 et seq.). Those materials not exempted under the ATCM must meet the specified emission limits, as shown in Table 5.504.4.5.</p> <p><b>5.504.4.5.3 Documentation.</b> Verification of compliance with this section shall be provided as requested by the enforcing agency. Documentation shall include at least one of the following:</p> <ol style="list-style-type: none"> <li>1. Product descriptions and specifications.</li> <li>2. Chain of custody certifications.</li> <li>3. Product labeled and meeting the Composite Wood Products regulation (see CCR Title 17, Section 93120, et seq.).</li> <li>4. Exterior grade products marked as meeting the PS-1 or PS-2 standards of the Engineered Wood Association, the Australian AS/NZS 2269 or European 636 3S standards.</li> <li>5. Other methods acceptable to the enforcing agency.</li> </ol>																																																																																																																				
Y	N/A	RESPON. PARTY	<p><b>TABLE 5.504.4.5 - FORMALDEHYDE LIMITS:</b></p> <table border="1"> <thead> <tr> <th colspan="2">MAXIMUM FORMALDEHYDE EMISSIONS IN PARTS PER MILLION</th> </tr> <tr> <th>PRODUCT</th> <th>CURRENT LIMIT</th> </tr> </thead> <tbody> <tr><td>HARDWOOD PLYWOOD VENEER CORE</td><td>0.05</td></tr> <tr><td>HARDWOOD PLYWOOD COMPOSITE CORE</td><td>0.05</td></tr> <tr><td>PARTICLE BOARD</td><td>0.09</td></tr> <tr><td>MEDIUM DENSITY FIBERBOARD</td><td>0.11</td></tr> <tr><td>THIN MEDIUM DENSITY FIBERBOARD<sub>2</sub></td><td>0.13</td></tr> </tbody> </table> <p>1. VALUES IN THIS TABLE ARE DERIVED FROM THOSE SPECIFIED BY THE CALIFORNIA AIR RESOURCES BOARD, AIR TOXICS CONTROL MEASURE FOR COMPOSITE WOOD AS TESTED IN ACCORDANCE WITH ASTM E 1333. FOR ADDITIONAL INFORMATION, SEE CALIFORNIA CODE OF REGULATIONS, TITLE 17, SECTIONS 93120 THROUGH 93120.12.</p> <p>2. THIN MEDIUM DENSITY FIBERBOARD HAS A MAXIMUM THICKNESS OF 5/16 INCHES (8 MM).</p> <p><b>5.504.4.6 Resilient flooring systems.</b> Where resilient flooring is installed, at least 80 percent of floor area receiving resilient flooring shall meet the requirements of the California Department of Public Health, "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350).</p> <p>See California Department of Public Health's website for certification programs and testing labs. <a href="https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material">https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material</a></p> <p><b>5.504.4.6.1 Verification of compliance.</b> Documentation shall be provided verifying that resilient flooring materials meet the pollutant emission limits.</p> <p><b>5.504.4.7 Thermal insulation.</b></p> <p>Comply with the requirements of the California Department of Public Health, "Standard Method of the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350). See California Department of Public Health's website for certification programs and testing labs. <a href="https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material">https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material</a></p> <p><b>5.504.4.7.1 Verification of compliance.</b> Documentation shall be provided verifying that thermal insulation materials meet the pollutant emission limits.</p> <p><b>5.504.4.8 Acoustical ceiling and wall panels.</b></p> <p>Comply with the requirements of the California Department of Public Health, "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350). See California Department of Public Health's website for certification programs and testing labs.</p> <p><b>5.504.4.8.1 Verification of compliance.</b> Documentation shall be provided verifying that acoustical finish materials meet the pollutant emission limits.</p> <p><b>5.504.4.8.3 Filters.</b> In mechanically ventilated buildings, provide regularly occupied areas of the building with air filtration media for outside and return air that provides at least a Minimum Efficiency Reporting Value (MERV) of 13. MERV 13 filters shall be installed prior to occupancy, and recommendations for maintenance with filters of the same value shall be included in the operation and maintenance manual.</p> <p><b>Exceptions:</b> Existing mechanical equipment.</p> <p><b>5.504.5.3.1 Labeling.</b> Installed filters shall be clearly labeled by the manufacturer indicating the MERV rating.</p> <p><b>5.504.7 ENVIRONMENTAL TOBACCO SMOKE (ETS) CONTROL.</b> Where outdoor areas are provided for smoking, provide a smoke-free 25-foot radius around air intakes and operable windows and within 10 feet of building as already prohibited by other laws or regulations, or as enforced by ordinances, regulations or policies of any city, county, city and county, California Community College, campus of the California State University, or campus of the University of California, whichever are more stringent. When ordinances, regulations or policies are not in place, post signage to inform building occupants of the prohibitions.</p> <p><b>SECTION 5.505 INDOOR MOISTURE CONTROL</b></p> <p><b>5.505.1 INDOOR MOISTURE CONTROL.</b> Buildings shall meet or exceed the provisions of California Building Code, CCR, Title 24, Part 2, Sections 1202 (Ventilation) and Chapter 14 (Exterior Walls). For additional measures, see Section 5.407.2 of this code.</p> <p><b>SECTION 5.506 INDOOR AIR QUALITY</b></p> <p><b>5.506.1 OUTSIDE AIR DELIVERY.</b> For mechanically or naturally ventilated spaces in buildings, meet the minimum requirements of Section 120.1 (Requirements For Ventilation) of the California Energy Code, or the applicable local code, whichever is more stringent, and Division 1, Chapter 4 of CCR, Title 8.</p> <p><b>5.506.2 CARBON DIOXIDE (CO<sub>2</sub>) MONITORING.</b> For buildings or additions equipped with demand control ventilation, CO<sub>2</sub> sensors and ventilation controls shall be specified and installed in accordance with the requirements of the California Energy Code, Section 120(c)(4).</p> <p><b>5.506.3 Carbon dioxide (CO<sub>2</sub>) monitoring in classrooms.</b> (DSA-3) Each public K-12 school classroom, as listed in Table 120.1-A of the California Energy Code, shall be equipped with a carbon dioxide monitor or sensor that meets the following requirements:</p> <ol style="list-style-type: none"> <li>1. The monitor or sensor shall be permanently affixed in a tamper-proof manner in each classroom between 3 and 6 feet (914 mm and 1829 mm) above the floor and at least 5 feet (1524 mm) away from door and operable windows.</li> <li>2. When the monitor or sensor is not integral to an Energy Management Control System (EMCS), the monitor or sensor shall display the carbon dioxide readings on the device. When the sensor is integral to an EMCS, the carbon dioxide shall be available to and readable by facility personnel.</li> <li>3. A monitor shall provide notification to a visual indicator on the monitor when the carbon dioxide levels in the classroom have exceeded 1,100ppm. A sensor integral to an EMCS shall provide notification to facility personnel through a visual and/or audible indicator when the carbon dioxide levels in the classroom have exceeded 1,100ppm.</li> <li>4. The monitor or sensor shall measure carbon dioxide levels at minimum 15- minute intervals and shall maintain a record of previous carbon dioxide measurements of not less than 30 days duration.</li> <li>5. The monitor or sensor shall have the capacity to measure carbon dioxide levels shall have the capacity to measure carbon dioxide levels with a range of 400ppm to 2000ppm or greater.</li> <li>6. The monitor or sensor shall be certified by the manufacturer to be accurate within 75ppm at 1,000ppm carbon dioxide concentration and shall be certified by the manufacturer to require calibration no more frequently than once every 5 years.</li> </ol> <p><b>5.506.4.3 Verification.</b> Verification of compliance with this section shall be provided at the request of the enforcing agency. Documentation may include, but is not limited to, the following:</p> <ol style="list-style-type: none"> <li>1. Manufacturer's product specification</li> <li>2. Field verification of on-site product containers</li> </ol> <p>All carpet installed in the building interior shall meet the requirements of the California Department of Public Health, "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350).</p> <p>See California Department of Public Health's website for certification programs and testing labs. <a href="https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material">https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material</a></p> <p><b>5.506.4.4 Carpet Systems.</b> All carpet cushion installed in the building interior shall meet the requirements of the California Department of Public Health, "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers," Version 1.2, January 2017 (Emission testing method for California Specifications 01350).</p> <p>See California Department of Public Health's website for certification programs and testing labs. <a href="https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material">https://www.cdph.ca.gov/Programs/CCDPHP/DEODC/EHLB/IAQ/Pages/VOC.aspx#material</a></p> <p><b>5.506.4.5 Documentation.</b> Documentation shall be provided verifying that the carpet and carpet cushion meet the requirements of Table 5.506.4.5.</p> <p><b>5.506.4.6 Verification.</b> Verification of compliance with this section shall be provided at the request of the enforcing agency. Documentation may include, but is not limited to, the following:</p> <ol style="list-style-type: none"> <li>1. Manufacturer's product specification</li> <li>2. Field verification of on-site product containers</li> </ol> <p><b>5.506.4.7 Carpet adhesive.</b> All carpet adhesive shall meet the requirements of Table 5.504.4.1.</p>	MAXIMUM FORMALDEHYDE EMISSIONS IN PARTS PER MILLION		PRODUCT	CURRENT LIMIT	HARDWOOD PLYWOOD VENEER CORE	0.05	HARDWOOD PLYWOOD COMPOSITE CORE	0.05	PARTICLE BOARD	0.09	MEDIUM DENSITY FIBERBOARD	0.11	THIN MEDIUM DENSITY FIBERBOARD <sub>2</sub>	0.13																																																																																																			
MAXIMUM FORMALDEHYDE EMISSIONS IN PARTS PER MILLION																																																																																																																				
PRODUCT	CURRENT LIMIT																																																																																																																			
HARDWOOD PLYWOOD VENEER CORE	0.05																																																																																																																			
HARDWOOD PLYWOOD COMPOSITE CORE	0.05																																																																																																																			
PARTICLE BOARD	0.09																																																																																																																			
MEDIUM DENSITY FIBERBOARD	0.11																																																																																																																			
THIN MEDIUM DENSITY FIBERBOARD <sub>2</sub>	0.13																																																																																																																			
<p><b>SECTION 5.507 ENVIRONMENTAL COMFORT</b></p> <p><b>5.507.4 ACOUSTICAL CONTROL.</b> Employ building assemblies and components with Sound Transmission Class (STC) values determined in accordance with ASTM E 90 and ASTM E 413, or Outdoor-Indoor Sound Transmission Class (OTC) determined in accordance with ASTM E 1332, using either the prescriptive or performance method in Section 5.507.4.1 or 5.507.4.2.</p> <p><b>Exception:</b> Buildings with few or no occupants or where occupants are not likely to be affected by exterior noise, as determined by the enforcement authority, such as factories, stadiums, storage, enclosed parking structures and utility buildings.</p> <p><b>Exception:</b> [DSA-SS] For public schools and community colleges, the requirements of this section and all subsections apply only to new construction.</p> <p><b>5.507.4.1 Exterior noise transmission, prescriptive method.</b> Wall and roof-ceiling assemblies exposed to the noise source making up the building or addition envelope or altered envelope shall meet a composite STC rating of at least 50 or a composite OTC rating of no less than 40, with exterior windows of a minimum STC of 40 or OTC of 30 in the following locations:</p> <ol style="list-style-type: none"> <li>1. Within the 65 CNEL noise contour of an airport.</li> </ol> <p><b>Exceptions:</b></p> <ol style="list-style-type: none"> <li>1. L<sub>dn</sub> or CNEL for military airports shall be determined by the facility Air Installation Compatible Land Use Zone (AICLU) plan.</li> <li>2. L<sub>dn</sub> or CNEL for other airports and heliports for which a land use plan has not been developed shall be determined by the local general plan noise element.</li> <li>2. Within the 65 CNEL or L<sub>dn</sub> noise contour of a freeway or expressway, railroad, industrial source or fixed-guideway source as determined by the Noise Element of the General Plan.</li> </ol> <p><b>5.507.4.1.1 Noise exposure where noise contours are not readily available.</b> Buildings exposed to a noise level of 65 dB L<sub>dn</sub> - 1 hr during any hour of operation shall have building, addition or alteration exterior wall and roof-ceiling assemblies exposed to the noise source meeting a composite STC rating of at least 45 (or OTC 30), with exterior windows of a minimum STC of 40 (or OTC 30).</p> <p><b>5.507.4.2 Performance Method.</b> For buildings located as defined in Section 5.507.4.1 or 5.507.4.1.1, wall and roof-ceiling assemblies exposed to the noise source making up the building or addition envelope or altered envelope shall be constructed to provide an interior noise environment attributable to exterior sources that does not exceed an hourly equivalent noise level (Leq-1hr) of 50 dBA in occupied areas during any hour of operation.</p> <p><b>5.507.4.2.1 Site Feature.</b> Exterior features such as sound walls or earth berms may be used as appropriate to the building, addition or alteration project to mitigate sound migration to the interior.</p> <p><b>5.507.4.2.2 Documentation of Compliance.</b> An acoustical analysis documenting interior soundlevels shall be prepared by personnel approved by the architect or engineer of record.</p> <p><b>5.507.4.3 Interior sound transmission.</b> Wall and roof-ceiling assemblies separating tenant spaces and tenant spaces and public places shall have an STC of at least 40.</p> <p><b>Note:</b> Examples of assemblies and their various STC ratings may be found at the California Office of Noise Control. <a href="http://www.toolbase.org/PDF/CaseStudies_icc_ratings.pdf">www.toolbase.org/PDF/CaseStudies_icc_ratings.pdf</a>.</p> <p><b>SECTION 5.508 OUTDOOR AIR QUALITY</b></p> <p><b>5.508.1 Ozone depletion and greenhouse gas reductions.</b> Installations of HVAC, refrigeration and fire suppression equipment shall comply with Sections 5.508.1.1 and 5.508.1.2.</p> <p><b>5.508.1.1 Chlorofluorocarbons (CFCs).</b> Install HVAC, refrigeration and fire suppression equipment that do not contain CFCs.</p> <p><b>5.508.1.2 Halons.</b> Install HVAC, refrigeration and fire suppression equipment that do not contain Halons.</p> <p><b>5.508.2 Supermarket refrigerant leak reduction.</b> New commercial refrigeration systems shall comply with the provisions of the section when installed in retail food stores, 8,000 square feet or more conditioned area, and that utilize either refrigerant cases, or walk-in coolers or freezers connected to remote compressor units or condenser units. The leak reduction measures apply to refrigeration systems containing high-global-warming potential (high-GWP) refrigerants with a GWP of 150 or greater. New refrigeration systems include both new facilities and the replacement of existing refrigeration systems in existing facilities.</p> <p><b>Exception:</b> Refrigeration systems containing low-global-warming potential (low-GWP) refrigerant with a GWP value less than 150 are not subject to this section. Low-GWP refrigerants are nonozone-depleting refrigerants that include ammonia, carbon dioxide (CO<sub>2</sub>), and potentially other refrigerants.</p> <p><b>5.508.2.1 Refrigerant piping.</b> Piping compliant with the California Mechanical Code shall be installed to be accessible for leak protection and repairs. Piping runs using threaded pipe, copper tubing with an outside diameter (OD) less than 1/4 inch, flared tubing connections and short radius elbows shall not be used in refrigerant systems except as noted below.</p> <p><b>5.508.2.1.1 Threaded pipe.</b> Threaded connections are permitted at the compressor rack.</p> <p><b>5.508.2.1.2 Copper pipe.</b> Copper tubing with an OD less than 1/4 inch may be used in systems with a refrigerant charge of 5 pounds or less.</p> <p><b>5.508.2.1.2.1 Anchorage.</b> One-fourth-inch OD tubing shall be securely clamped to a rigid base to keep vibration levels below 8 mils.</p> <p><b>5.508.2.1.2.3 Flared tubing connections.</b> Double-flared tubing connections may be used for pressure controls, valves, pilot lines and oil.</p> <p><b>Exception:</b> Single-flared tubing connections may be used with a multilip seal coated with industrial sealant suitable for use with refrigerants and tightened in accordance with manufacturer's recommendations.</p> <p><b>5.508.2.1.4 Elbows.</b> Short radius elbows are only permitted where space limitations prohibit use of long radius elbows.</p> <p><b>5.508.2.2 Valves.</b> Valves Valves and fittings shall comply with the California Mechanical Code and as follows:</p> <p><b>5.508.2.2.1 Pressure relief valves.</b> For vessels containing high-GWP refrigerant, a rupture disc shall be installed between the outlet of the vessel and the</p>																																																																																																																				